

CENTRAL INTELLIGENCE AGENCY

INFORMATION REPORT

This material contains information affecting the National Defense of the United States within the meaning of the Espionage Laws, Title 18, U.S.C. Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law.

50X1

50X1

 $C-O-N-F-I-D-E-N_{\overrightarrow{U}}T-I-A-L$

COUNTRY SUBJECT DATE OF INFO	o.		sia_ nt for Strong chinery in B	REPORT NO. DATE DISTR. NO. OF PAGES REQUIREMENT NO. REFERENCES	26 April 1955 3
			RCE EVALUATIONS II THE APPRAISAL OF ((FOR KEY	TATIVE.	
50X1 50X1 50X1 50X1	Attached	is	as received		
50X1					

C-O-N-F-I-D-E-N-T-I-A-L

50X1

STATE #X ARMY #X NAVY #X AIR #X FBI AEC

(NOTE: Washington distribution indicated by "X"; Field distribution by "#".)

			C-O-N-F-I-D-E-N-T-I-A-L	REPORT		
					50X1	
			50X1			
(COUNTRY	Czechoslova	kia	DATE DISTR.	DATE DISTR. 27 Dec 1954	
	SUBJECT	Testing Plan Electric Ma	NO. OF PAGES 2			
	DATE OF INFORMATION		50X′	REFERENCES:		
F	PLACE ACQU	IRED			•	
		• 4	THIS IS UNEVALUATED INFORMATION 50X1			

1. There was a plant for testing strong-current electric machinery in Bechovice (N 50-05. E 14-37). (For approximate location see sketch. page 2

50X1 **page** 2

50X1

50X1

The plant was part of the Research Institute of the Ministry of Machinery Construction, Strong-Current Division, in Prague II, Opletal Street. The Bechovice plant had a department for testing large three-phase switches in short circuit, such as those used in power plants, and 3000 volt, DC railroad switches in short circuit. The main equipment in this department was as follows:

a. Two synchronous generators, each rated at 1,000 kw-amp., continuous output 3,000 rpm, voltage unknown

b. Each generator had two exciters, each rated at 750 v, 516 amp., possible short-time voltage 900 v. Each exciter was insulated against the ground at 3,600 v. When connected in series, the four exciters gave off 3,600 v, which voltage was necessary for testing railroad switches. (Czechoslovakia used 3,000 v DC on its electric railroads.) Originally the preliminary designing for the exciters and the manufacturing was to be done by MEZ Vsetin whereas the physical designing was to be done by MEZ Development in Brno. Dr. Bedrich Heller, manager of the Strong-Current Division of the Research Institute, and Ing. Hassdenteufel (fnu), who was designated to become manager of the Bechovice testing plant, visited MEZ Vsetin several times in early 1949, at the time that construction of the testing plant in Bechovice was begun, to

discuss the order. The exciters were to be delivered during 1950; however, Ing. Klima, manager of MEZ Development, was against accepting the order, pointing out that CKD Stalingrad already had designed a similar type of exciter. Finally, the exciters were delivered by CKD Stalingrad.

C-O-N-F-I-D-E-N-T-I-A-L

derivered by our buarringrad.

C-O-N-F-I-D-E-N-T-I-A-L- 2 -

MEZ Vsetin delivered standard DC motors and generators for the entire Bechovice testing plant, all of which were the smallest sizes in the 50X1 middle-size category, and one or two small dynamometers which were 50X1 not for excessively high speeds.1 50X1 50X1

all of the machinery which had been ordered reached the Bechovice testing plant before summer 1954.

the department for testing large switches, both for power plants and railroads, was the only one of its type in 3. 50X1 Czechoslovakia and that the other departments of the Bechovice plant were standard testing departments; the types and character of machinery delivered to becnowice by MEZ Vsetin.


50X1

During 1953 or early 1954, MEZ Vsetin was approached for information concerning the possibility of manufacturing a DC motor for a leather 50X1 belt drive for a Van de Graaff generator. 50X1 50X1 the Van de Graaff generator

was to be built in Bechovice.

50X1

50X1



5547

C-O-N-F-I-D-E-N-T-I-A-L